

TECHNICAL SPECIFICATIONS FOR UPS

	Purchaser's Requirements	Priority	Bidder's Offer		
			Conformity		Remarks
			Yes	No	
1	Brand	C			
2	Make	C			
3	Model	C			
4	County Of Origin	C			
5	Capacity	650VA			
6	Input Voltage	140 - 300V 5VAC			
8	Output Voltage	230VAC +10% -10			
9	Battery Mode	230VAC +10% -10			
10	Transfer Time	2ms 2-6ms			
11	Frequency(Battery Mode)	50/60Hz			
12	Backup Time	7 ~ 15minutes depending on load			
	Recharge Time	90% capacity after 5 hours			
13	Surge Protection	Yes			
14	Battery Management	Prevent overcharging			
16	Warranty & service	Comprehensive on-site warranty for 24 months (Labor & Parts) Excluding Consumes.			
17	Warranty Information	Should be fix a sticker with -Supplier name,Contact Numbers,Date of Commissioning of Hardware,Warranty period In UPS			
18	Technical literature in English describing the equipment offered and details of the equipment specifications shall be supplied with the offer				
19	Unit Price	Rs.....			

Information given under "Bidder's Offer" is true & correct.

Bidder/s Name, Signature & Date :

Company Seal :